

ABOVE CODE ENERGY ENHANCEMENT PROJECT
for
The City of Arlington

February 2012



ENERGY SYSTEMS LABORATORY

**Texas Engineering Experiment Station
The Texas A&M University System**



ENERGY SYSTEMS LABORATORY

Project Goals

- ▶ Identify Energy Efficient Measure (EEM) combinations that achieve 15% above current energy code requirements
- ▶ Examine the relationship between cost of the EEMs and simple return on investment
- ▶ Determine the impact on air quality through emission reduction
- ▶ Estimate consumer energy savings through the use of EEM combinations – lower utility bills
- ▶ Improve quality of construction



Types of Buildings Modeled

▶ Residential

- ▶ 2,325 ft², square-shape, one-story, single-family detached house
- ▶ 50% Energy Star permanent CFL or fluorescent lamps
- ▶ HVAC and duct systems in unconditioned attic

▶ Small Office

- ▶ 20,000 ft², square-shape, two-story, office building
- ▶ Wood frame construction
- ▶ 20% window-to-wall ratio
- ▶ Packaged rooftop air conditioner (CAV, DX, gas furnace)



Types of Buildings Modeled

▶ Small Retail

- ▶ 15,000 ft², one-story, strip mall building
- ▶ Concrete tilt wall construction
- ▶ 70% WWR for front wall only (28% WWR for an entire building)
- ▶ Packaged rooftop air conditioner (CAV, DX, gas furnace)

▶ Restaurant

- ▶ 5,500 ft², one-story, building – Dining space modeled (4,000 ft²)
 - ▶ Steel frame construction
 - ▶ 35% WWR for front wall only (17% WWR for an entire building)
 - ▶ Packaged rooftop air conditioner (CAV, DX, gas furnace)
 - ▶ Dining space modeled for assessment of energy efficiency measures
-



Energy Efficiency Measures - Residential

▶ Envelope and Fenestration

1. Radiant Barriers in Attics (with ducts in attics)
2. Sealed (Unvented) Attic
3. Window Shading (none to 2 ft. eaves on all sides)
4. Window Shading and Distribution
5. Decreased Window SHGC
6. Decreased Window U Value
7. Decreased Window SHGC & U Value

▶ HVAC System Measures

8. Relocate Mechanical Systems within Conditioned Space
9. Improved Air Conditioner SEER/Improved Heat Pump Efficiency
10. Improved Furnace Efficiency

▶ Domestic Hot Water Measures

11. Tankless Gas Water Heater
12. Removal of Pilot Light from Domestic Hot Water System
13. Solar Domestic Hot Water System (30 sq ft collector, 65 gal tank)
14. Solar Domestic Hot Water System (64 sq ft collector, 80 gal tank)

▶ Lighting Measures

15. 75% Energy Star Permanent CFL or Fluorescent Indoor Lamps
16. 100% Energy Star Permanent CFL or Fluorescent Indoor Lamps

▶ Renewable Power Measures

17. 4 kW Photovoltaic Array
-



Energy Efficiency Measures - Commercial

▶ Envelope

1. Wall Insulation
2. Roof Insulation
3. Roof Exterior
4. Window U-Value
5. Window Re-Distribution
6. Window Shading
7. Window Shading and Re-Distribution
8. Air Barrier

▶ Interior Lighting

9. Lighting Power Density
10. 24-Hour Lighting
11. Daylighting Control
(Sidelighting)

▶ Exterior Lighting

12. Parking Lots
Façade & Landscape Lighting
Building Entrance (w/o canopy)
Building Exit
Extra Power Allowance
Exterior Lighting Controls

▶ HVAC Systems

13. HVAC System Efficiency
14. Fan Efficiency
15. Economizer
16. Furnace Efficiency
17. Demand Control Ventilation System

▶ Service Hot Water Systems

18. Efficient Water Heaters



Residential

Energy Efficient Measures – Best Combination

- ▶ 100% Energy Star Permanent CFLs, or Fluorescent Indoor Lamps
- ▶ Decreased Window SHGC (from .3 to .2) and U-value (from .5 to .3)
- ▶ Radiant Barrier in attics (with ducts and AC equipment in the attic)

<u>EEM Cost</u>	<u>% of project</u>	<u>ROI</u>	<u>Emissions Savings</u>
\$1,250 to \$2,195	.75 to 1.3%	3.1-5.4 yrs	NO _x = 5.8 lbs/year SO ₂ = 3.9 lbs/year CO ₂ = 2.4 tons/year

Estimated Energy Savings = \$403 per year

Emission Savings equivalent to removing passenger vehicles/year¹

- ▶ NO_x = 0.16 vehicles
- ▶ CO₂ = 0.42 vehicles



Small Office

Energy Efficient Measures – Best Combination

- ▶ Daylight dimming control
- ▶ Decreased lighting power density (from 1.0 to 0.75 w/ft²)
- ▶ Improved fan efficiency (from 55% to 65%)

<u>EEM Cost</u>	<u>% of project</u>	<u>ROI</u>	<u>Emissions Savings</u>
\$28,644 to \$42,966	.14 to 2.4%	8.4-12.7 yrs	NO _x = 24.7 lbs/year SO ₂ = 15.5 lbs/year CO ₂ = 20.85 tons/year

Estimated Energy Savings = \$2,812/yr; Estimated Demand Savings = \$583/yr

Emission Savings equivalent to removing passenger vehicles/year¹

- ▶ NO_x = 0.65 vehicles
- ▶ CO₂ = 3.65 vehicles



Small Retail

Energy Efficient Measures – Best Combination

- ▶ Decreased lighting power density (from 1.5 to 1.25 w/ft²)
- ▶ Daylight dimming control

<u>EEM Cost</u>	<u>% of project</u>	<u>ROI</u>	<u>Emissions Savings</u>
\$18,872 to \$28,307	1.3 to 1.9%	5.2-7.8 yrs	NO _x = 27.3 lbs /year SO ₂ = 32.2 lbs /year CO ₂ = 43.3 tons/year

Estimated Energy Savings = \$3,062/yr; Estimated Demand Savings = \$580/year

Emission Savings equivalent to removing passenger vehicles/year¹

- ▶ NO_x = 0.71 vehicles
- ▶ CO₂ = 7.56 vehicles



Restaurant

Energy Efficient Measures – Best Combination

- ▶ Reduced lighting power density (from 1.6 to 0.89 w/ft²)
- ▶ Exterior lighting power reduction (from 3.61 kw to 2 kw and reduction in usage to 25% of current usage from 12:00 AM to 6:00 AM)

<u>EEM Cost</u>	<u>% of project</u>	<u>ROI</u>	<u>Emissions Savings</u>
\$8,480 to \$12,720	.8 to 1.2%	2.4-3.5 yrs	NO _x = 0.025 tons/year SO ₂ = 0.014 tons/year CO ₂ = 19.6 tons/year

Estimated Energy Savings = \$3,362/yr; Estimated Demand Savings = \$236

Emission Savings equivalent to removing passenger vehicles/year¹

- ▶ NO_x = 1.31 vehicles
- ▶ CO₂ = 3.42 vehicles



Final Reports Document Each Building Type


ESL-TR-11-10-08

**COST-EFFECTIVE ENERGY EFFICIENCY MEASURES
FOR ABOVE CODE (ASHRAE 90.1-2001 and 2007):
FOR RESTAURANT BUILDINGS IN THE CITY OF ARLINGTON**

A Research Project for the City of Arlington

Jaya Mukhopadhyay
Hyojin Kim
Sung Lok Do
Kee Han Kim
Juan-Carlos Baltazar, Ph.D.
Jeff S. Haberl, Ph.D., P.E.
Cynthia Lewis

October 2011
Revised December 2011



ENERGY SYSTEMS LAB
Texas Engineering Experiment
The Texas A&M University System


ESL-TR-11-10-07

**COST-EFFECTIVE ENERGY EFFICIENCY MEASURES
FOR ABOVE CODE (ASHRAE 90.1-2001 and 2007):
SMALL OFFICE BUILDINGS IN THE CITY OF ARLINGTON**

A Research Project for the City of Arlington

Hyojin Kim
Sung Lok Do
Kee Han Kim
Juan-Carlos Baltazar, Ph.D.
Jeff S. Haberl, Ph.D., P.E.
Cynthia Lewis

October 2011
Revised December 2011



ENERGY SYSTEMS LABORATORY
Texas Engineering Experiment Station
The Texas A&M University System


ESL-TR-11-10-02

**COST-EFFECTIVE ENERGY EFFICIENCY MEASURES
FOR ABOVE CODE (ASHRAE 90.1-2001 and 2007):
SMALL RETAIL BUILDINGS IN THE CITY OF ARLINGTON**

A Research Project for the City of Arlington

Hyojin Kim
Sung Lok Do
Kee Han Kim
Juan-Carlos Baltazar, Ph.D.
Jeff S. Haberl, Ph.D., P.E.
Cynthia Lewis

October 2011
Revised December 2011



ENERGY SYSTEMS LABO
Texas Engineering Experiment S
The Texas A&M University Syst


ESL-TR-11-07-01

**COST-EFFECTIVE ENERGY EFFICIENCY MEASURES
FOR ABOVE CODE (2003 AND 2009 IECC):
RESIDENTIAL BUILDINGS IN THE CITY OF ARLINGTON**

A Research Project for the City of Arlington

Hyojin Kim
Sung Lok Do
Juan-Carlos Baltazar, Ph.D.
Jeff S. Haberl, Ph.D., P.E.
Cynthia Lewis

July 2011
Revised December 2011



ENERGY SYSTEMS LABORATORY
Texas Engineering Experiment Station
The Texas A&M University System



ENERGY SYSTEMS LABORATORY

Questions?



Next Steps

- ▶ Marketing Plan Development
 - ▶ Web Page – Are you Above Code?
 - ▶ Energy Efficiency Information
 - ▶ Videos
 - ▶ Series that describes EEM's and possible ROI
 - ▶ Distribution to Contractors through professional organization
 - ▶ Press Release
 - ▶ Explore Partnership Opportunities
 - ▶ MyArlingtontx.com
 - ▶ Article
 - ▶ Social Media
 - ▶ Facebook/Twitter