



28' CONCRETE RURAL SECTION  
TYPICAL CROSS SECTION

NTS

- NOTES: 1. TRANSVERSE SAWED CONTRACTION JOINT AT 12' INTERVALS FOR CONCRETE PAVEMENT.
- \* 2. LIME SHALL BE APPLIED AT 6% BY WEIGHT MINIMUM QUANTITY IS 36#/SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
3. BAR DITCH SIDE SLOPE VARIES DEPENDING UPON DESIGN, NO GREATER THAN 3:1 WITHOUT AMORING.
- \*\* 4. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 30#/SY.

DATE	REVISION
11/13/09	REVISED
CITY OF ARLINGTON, TEXAS	
PROJECT NUMBER	
PROJECT NAME	
(PROJECT LIMITS)	
DESIGNED BY	CHECKED BY
DRAWN BY	DATE