



28' H.M.A.C. PAVEMENT SECTION  
TYPICAL CROSS SECTION

NTS

- NOTES: \*
1. LIME SHALL BE APPLIED AT 6 % BY WEIGHT MINIMUM QUANTITY IS 5#/SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
  2. BAR DITCH SIDE SLOPE VARIES DEPENDING UPON DESIGN, NO GREATER THAN 3:1 WITHOUT ARMORING.
  3. FOR 30" GUTTER DETAIL, SEE CURB & GUTTER DETAILS.
  - \*\* 4. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 45#/SY.

APPROVED	DATE	SCALE	REVISION
	11/16/09	AS SHOWN	REV. 1
CITY OF ARLINGTON, TEXAS			
PROJECT NUMBER			
PROJECT NAME			
(PROJECT LIMITS)			
DATE	SCALE	REVISION	
11/16/09	AS SHOWN	REV. 1	