



28' CONCRETE PAVEMENT SECTION  
TYPICAL CROSS SECTION

NTS

NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINT AT 12' INTERVALS FOR CONCRETE PAVEMENT.
- \*2. LIME SHALL BE APPLIED AT 6 % BY WEIGHT MINIMUM QUANTITY IS 45LBS./SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
- \*\*3. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 30LBS./SY.



CITY OF ARLINGTON, TEXAS

28' CONCRETE SECTION

DATE:	SCALE: NTS	SHEET OF
DESIGNED BY:	DRAWN BY:	CHECKED BY: