



### 45' CONCRETE PAVEMENT SECTION TYPICAL CROSS SECTION

NTS

**NOTES:**

1. TRANSVERSE SAWED CONTRACTION JOINT AT 15' INTERVALS & LONGITUDINAL SAWED CONTRACTION JOINTS AT 11' INTERVALS FOR CONCRETE PAVEMENT.
- \* 2. LIME SHALL BE APPLIED AT 6% BY WEIGHT MINIMUM QUANTITY IS 45LBS./SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
- \*\* 3. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 30LBS./SY.



CITY OF ARLINGTON, TEXAS

### 45' CONCRETE SECTION

DATE:	SCALE: NTS	SHEET ___ OF ___
DESIGNED BY:	DRAWN BY:	CHECKED BY: