



THE PIPE SHALL BE BEDDED IN A MINIMUM OF SIX INCHES (6") OF CRUSHED STONE. IN WET OR UNSTABLE TRENCHES, ADDITIONAL CRUSHED STONE WILL BE ADDED TO THE STANDARD BEDDING REQUIREMENTS AS NEEDED. CRUSHED STONE SHALL MEET C.O.G. 2.1.8 STANDARD CRUSHED ROCK - AGGREGATE GRADE 4.

AFTER THE PIPE HAS BEEN LAID AND THE JOINTS MADE, CRUSHED STONE SHALL BE PLACED FROM THE BOTTOM OF THE PIPE TO OVER THE TOP OF THE PIPE. THE MATERIAL SHALL BE PLACED UNIFORMLY ON BOTH SIDES OF THE PIPE IN ORDER TO PREVENT DISTURBANCE OF THE PIPE AND, IF NECESSARY, BLOCKING SHALL BE PLACED AGAINST THE SIDES OF THE TRENCH TO PREVENT DISPLACEMENT OF THE PIPE. THE MATERIAL SHALL BE WORKED UNDER THE HAUNCHES OF THE PIPE DURING THE TIME IT IS BEING PLACED. FILTER FABRIC SHALL BE PLACED OVER THE FULL WIDTH OF THE EMBEDMENT PRIOR TO TRENCH BACKFILL OPERATIONS.

FOR THE SPECIFICATIONS FOR THE REMAINING BACKFILL OPERATIONS, SEE THE TRENCH BACKFILL SPECIAL PROVISION.

RCP STORM DRAIN EMBEDMENT
NTS

 CITY OF ARLINGTON, TEXAS		
EMBEDMENT		
DATE:	SCALE: NTS	SHEET ____ OF ____
DESIGNED BY:	DRAWN BY:	CHECKED BY: