



SIDEWALK WITH LOW WALL
NTS

NOTES:

1. STEEL REINFORCING IN WALL SHALL BE #3 BARS @ 12" CENTERS HORIZONTALLY AND #4 BARS @ 8" CENTERS VERTICALLY.
2. REDWOOD JOINTS IN WALL SHALL MATCH REDWOOD JOINTS IN THE SIDEWALK. THE WALL SHALL BE DOUBLE CHAMFERED AT THE REDWOOD LOCATIONS.
3. ENDS OF WALL SHALL ALSO BE CHAMFERED.
4. CONCRETE TO HAVE COMPRESSIVE STRENGTH OF 3600 PSI AT 28 DAYS.
5. PRE-MOLDED MATERIAL WITH REMOVABLE CAP STRIP. SEAL WITH NON-SAG GRAY SILICONE SEALANT, TXDOT CLASS 4 PREQUALIFIED JOINT SEALER.
6. EXPOSED FACE OF WALL SHALL HAVE FORMLINER FINISH.



CITY OF ARLINGTON, TEXAS

SIDEWALK WITH LOW WALL

DATE:	SCALE: NTS	SHEET _____ OF _____
DESIGNED BY:	DRAWN BY:	CHECKED BY: