


**PLAN**



**ELEVATION**

MINIMUM VAULT AND PIPING DIMENSIONS*				
METER	A (10 $\phi$ MIN.)	B*	MIN. C*	MIN. D
3"	30" (MIN.)	23"	4'-11"	4'-0"
4"	40" (MIN.)	28"	5'-4"	4'-0"
6"	60" (MIN.)	45 1/4"	6'-9"	4'-0"
8"	80" (MIN.)	52"	7'-4"	4'-6"
10"	100" (MIN.)	67 1/4"	8'-7"	4'-6"

**NOTES**

1. PIPING & BENDS IN METER VAULT SHALL BE FLANGED DUCTILE IRON, CLASS 350. OTHER PIPING & FITTINGS SHALL BE RESTRAINED MJ OR FLANGED DUCTILE IRON.
2. CONTACT METER SERVICES MGR. @ 817-459-5900 FOR CURRENT INFORMATION ON METERS & VAULTS PRIOR TO DESIGN OF METER FACILITY. VAULTS MAY BE CONSTRUCTED OF CAST-IN-PLACE OR PRECAST CONCRETE OR PLASTIC AS APPROVED BY THE CITY.
3. CONTRACTOR SHALL PURCHASE METER, STRAINER, & 2" METER BOX FROM CITY.
4. METER VAULT SHALL NOT BE INSTALLED IN EXISTING OR PROPOSED SIDEWALKS, DRIVEWAYS, PAVEMENTS OR ANY TRAFFIC AREAS.
5. ACCESS HATCH FOR METER VAULT SHALL BE 3'-6" X 3'-6" AS MANUFACTURED BY BILCO OR APPROVED EQUAL. HATCH SHALL BE LOCATED FOR EASE OF ENTRY AND ACCESS TO METER.
6. TOP OF VAULT SHALL BE 2" ABOVE GROUND WITH DRAINAGE SLOPING DOWN AWAY FROM VAULT.
7. METER BYPASSES ARE ONLY ALLOWED ON ONE-WAY FEEDS.

\*SEE NOTE 2. METER LENGTH (B) MAY CHANGE ANNUALLY AND WILL AFFECT MIN. VAULT LENGTHS (C). DIMENSIONS SHOWN ARE FOR DOMESTIC METERS ONLY. IRRIGATION METERS HAVE SHORTER DIMENSIONS.

**FIGURE 13**  
**TYPICAL METER VAULT & APPURTENANCES**  
**ARLINGTON WATER UTILITIES**