



NOTES:

1. CLASS "B" EMBEDMENT REQUIRED FOR SEWER MAIN AND SERVICE LINE WITHIN EASEMENT OR ROW UNLESS OTHERWISE NOTED.
2. SERVICES SHALL BE SDR-26 PVC PIPE.
3. NEW SERVICE TAPS ON EXISTING MAINS REQUIRE INSERTA-TEE CONNECTION OR APPROVED EQUAL.
4. SERVICES 6" AND LARGER REQUIRE A MANHOLE TO CONNECT TO MAIN.
5. STAMPING AND ETCHING CURB WITHIN CITY OF ARLINGTON ENTERTAINMENT DISTRICT IS NOT ALLOWED. BENCHMARK MEDALLION MAY BE USED IN LIEU OF STAMPING OR ETCHING.

ELEVATION

(PLAN VIEW SAME AS SANITARY SEWER SERVICE ON FIGURE 23)

FIGURE 24
DEEP SANITARY SEWER SERVICE
ARLINGTON WATER UTILITIES