

BRUSH PAINT (DO NOT SPRAY) MARKER AND PIPE WITH TWO COATS OF FLYNT READY MIXED ALUMINUM PAINT BY FLYNT PAINT PRODUCTS, GREENVILLE, TEXAS 1-800-473-5968 OR APPROVED EQUAL.

CLOSE PIPE END AND WELD TO MARKER (SEE ABOVE)

1/4" STEEL PLATE (TYPICAL OF ALL MARKERS)

2" GALVANIZED PIPE

CLASS "B" CONCRETE (2,000 PSI)


5'-8"

2'-0"


3"

8" DIA.


6" MIN.




**TAP MARKER**



**BLOW - OFF MARKER**



**GATE VALVE MARKER**



**AIR VALVE MARKER**

ADD THE FOLLOWING ON EACH MARKER IN BLACK PAINT WITH STENCILED OR EQUAL LETTERS:

COA WATER DEPT.  
817-459-5900

MARKERS REQUIRED ONLY IN UNDEVELOPED AREAS OR AT DIRECTION BY ARLINGTON WATER UTILITIES.

**FIGURE 4**  
WATER LINE MARKERS FOR  
MAINS IN UNDEVELOPED AREAS  
ARLINGTON WATER UTILITIES