



NOTES

1. ALL PIPING, FITTINGS, AND VALVES SHOWN ARE FOR 2" COMBINATION AIR VALVE. FOR COMBINATION AIR VALVE INSTALLATION LARGER THAN 2", ALL PIPING, FITTINGS, AND VALVES SHALL BE SAME SIZE AS AIR VALVE.
2. ALL ABOVE GROUND METAL PIPING, FITTINGS, SIGNS, ETC., SHALL BE BRUSH PAINTED WITH TWO COATS OF GREEN PAINT TO MATCH STEEL PLATE LID.
3. WRAP SERVICE SADDLE WITH TWO LAYERS OF POLYETHYLENE ENCASEMENT PER SECTION B17.
4. VAULT SIZE MAY BE INCREASED BY DESIGN TO ACCOMMODATE LARGER AIR VALVE SIZES, IF NEEDED. MUST BE APPROVED BY ENGINEER.
5. LID REQUIRES SET BOLTS USING 4 EACH 3/8-16 X 1.5" 18-8 STAINLESS STEEL TAP BOLT THREADED INTO SIDE OF STEEL LID.

REV: 02/16/12

FIGURE 9
2" COMBINATION AIR VALVE INSTALLATION
ARLINGTON WATER UTILITIES